



✓	Poles	A±0.30	B±0.20	17	85.50	80.0
02	10.50	5.0	18	90.50	85.0	
03	15.50	10.0	↓	Poles	A±0.45	B±0.35
04	20.50	15.0	19	95.50	90.0	
05	25.50	20.0	20	100.50	95.0	
06	30.50	25.0	21	105.50	100.0	
↓	Poles	A±0.35	B±0.25	22	110.50	105.0
07	35.50	30.0	23	115.50	110.0	
08	40.50	35.0				
09	45.50	40.0	↓			
10	50.50	45.0				
11	55.50	50.0				
12	60.50	55.0				
↓	Poles	A±0.40	B±0.30			
13	65.50	60.0				
14	70.50	65.0				
15	75.50	70.0				
16	80.50	75.0				

Screws Torque: 7.0 In-Lb
 Wire Range: 14~18 AWG
 Rated: 15 Amperes, AC250V
 Operation Temperature: -55°C~+100°C
 Insulation withstands volt: AC2000V min
 Insulation resistance: >1000MΩ/DC500V

Part Number:
TS-504-XXP
 02~23 Poles

Material	Plating/Finish	Remark
A Insulating body	PA66 UL 94V-0	Green
B Terminal	Brass	Tin
C Screw	Steel	Zinc
D Clamp	Brass	Nickel
E		

- △1 Size update From 3.5 to 3.9 (2020/08/28)
- △2 Size update From 13.4 to 13.3 (2019/04/12)
- △3 Size update From 15.34 to 15.40 (2019/04/12)

		DESIGN	CHECK	APPROVED	DRAWING NO.	PART NAME	UNIT	REVISION
		DATE	DATE	DATE		Terminal Blocks	MM	
		DATE	DATE	DATE		CERTIFIED		SHEET
		2009/09/03						1/1