



ZONE		REV	DESCRIPTION	DATE	APPROVED

✓	Poles	A±0.30	B±0.20		17	144.76	137.16
	02	30.46	22.86		18	152.38	144.78
	03	38.08	30.48	↓	Poles	A±0.45	B±0.35
	04	45.70	38.10		19	160.00	152.40
	05	53.32	45.72		20	167.62	160.02
	06	60.94	53.34		21	175.24	167.64
↓	Poles	A±0.35	B±0.25		22	182.86	175.26
	07	68.56	60.96		23	190.48	182.88
	08	76.18	68.58		24	198.10	190.50
	09	83.80	76.20	↓	Poles	A±0.50	B±0.40
	10	91.42	83.82		25	205.72	198.12
	11	99.04	91.44		26	213.34	205.74
	12	106.66	99.06		27	220.96	213.36
↓	Poles	A±0.40	B±0.30		28	228.58	220.98
	13	114.28	106.68		29	236.20	228.60
	14	121.90	114.30		30	243.82	236.22
	15	129.52	121.92				
	16	137.14	129.54				

Screws Torque: 12 In-Lb
 Wire Range: 16~22 AWG
 Rated: 15 Amperes.AC300V
 Operation Temperature: -55°C~+105°C
 Insulation withstands volt: AC2000V min
 Insulation resistance: >1000MΩ DC500V

Part Number:

FTB-707-□PH-□

02~30 Poles With Cover

	Material	Plating/Finish	Remark
A	Insulating body PA66 94V-0	PA66	Black
B	Terminals Brass	Tin	
C	Screws Steel	Nickel	
D	Cover PC		
E			

Size update From 9.6 to 9.5 (2021/10/15)



HOW DER
ELECTRONIC CO.,LTD

PART NAME UNIT REVISION

Terminal Blocks MM

DESIGN	CHECK	APPROVED	DRAWING NO.	CERTIFIED	SHEET
DATE 2009/09/03	DATE	DATE	7076217		1/1

